

| Unit | Tag | Spec / Treatment | Width | Height | Control | Chain Length | Notes | |
|------|---------|-----------------------|--------|---------|---------|--------------|--|--|
| 110 | B | Manual Dual - Ceramic | 40.25 | 74 | Right | 96 | missing fascia and brackets | |
| 111 | A | Manual Dual - Ceramic | 39.375 | 73.25 | Left | 94 | missing fascia and brackets | |
| 120 | B RIGHT | Manual Dual - Ceramic | 61.875 | 107.5 | Right | 150 | missing fascia, shade and brackets | |
| 201 | | Manual Dual - Plaster | 75 | 93.125 | Left | 126 | too wide, made at 76.5 wide but measure was 72 5/8 | |
| 306 | B LEFT | Manual Dual - Plaster | 62.375 | 106.625 | Left | 148 | missing fascia, need at 63 7/8 | |
| 308 | | Manual Dual - Plaster | 62.5 | 92.65 | | | too narrow at 61.25, remake at 62.58 width | |
| 316 | | Manual Dual - Plaster | 60.875 | 107 | Right | 148 | 316 fascia was sent 60.25" but needs 62.375 | |
| 401 | | Manual Dual - Plaster | 71.75 | 107 | Left | 148 | shade and fascia are too narrow, bracket to bracket is 72 7/8" | |
| 500 | | Manual Dual - Plaster | 90.625 | 103.625 | Right | 144 | too narrow make at 95" finished width, was measured 95.25x89.625 | |